

AS 3851—1991

Australian Standard<sup>®</sup>

---

**The calculation of short-circuit  
currents in three-phase  
a.c. systems**

---

This Australian Standard was prepared by Committee EL/7, Power Switchgear. It was approved on behalf of the Council of Standards Australia on 7 August 1990 and published on 13 May 1991.

---

The following interests are represented on Committee EL/7:

Australian British Chamber of Commerce  
Australian Electrical and Electronic Manufacturers Association  
Confederation of Australian Industry  
Electricity Supply Association of Australia  
Institution of Engineers, Australia  
Railways of Australia Committee  
Testing Authorities  
Workcover Authority, New South Wales

---

**Review of Australian Standards.** To keep abreast of progress in industry, Australian Standards are subject to periodic review and are kept up to date by the issue of amendments or new editions as necessary. It is important therefore that Standards users ensure that they are in possession of the latest edition, and any amendments thereto.

Full details of all Australian Standards and related publications will be found in the Standards Australia Catalogue of Publications; this information is supplemented each month by the magazine 'The Australian Standard', which subscribing members receive, and which gives details of new publications, new editions and amendments, and of withdrawn Standards.

Suggestions for improvements to Australian Standards, addressed to the head office of Standards Australia, are welcomed. Notification of any inaccuracy or ambiguity found in an Australian Standard should be made without delay in order that the matter may be investigated and appropriate action taken.

---

*This Standard was issued in draft form for comment as DR 88077.*

AS 3851—1991

Australian Standard<sup>®</sup>

---

**The calculation of short-circuit  
currents in three-phase  
a.c. systems**

---

First published as AS 3851—1991.

Incorporating:  
Amdt 1—1992

PUBLISHED BY STANDARDS AUSTRALIA  
(STANDARDS ASSOCIATION OF AUSTRALIA)  
1 THE CRESCENT, HOMEBUSH, NSW 2140

ISBN 0 7262 6515 2

## PREFACE

This Standard was prepared by the Standards Australia Committee on Power Switchgear, in response to requests from the industry for standard methods suitable for both manual and computer calculation of prospective short-circuit currents.

It is based technically on the following IEC documents and acknowledgement is made of the assistance received from these documents:

73(Central Office)5: Draft—Short-circuit calculation in three-phase a.c. systems

73(Central Office)17: Draft—Application guide for the calculation of short-circuit currents in low-voltage radial systems neglecting the influence of motors

IEC 865: Calculation of the effects of short-circuit currents

The editorial presentation of this Standard does not follow these IEC documents but adopts a concise and systematic approach which should be more readily understood by non-specialist electrical engineers and students of electrical engineering.

The calculation procedure is divided into two basic steps—

- (a) calculating the impedances of the circuit elements from their characteristics independent of the fault; and
- (b) the calculation of fault currents from the fault voltage and impedances.

This Standard is concerned with the calculation of the current in the fault. The distribution of resulting currents in the network would need to be determined from detailed circuit analysis.

The major differences between this Standard and the above IEC documents are as follows:

- (i) The IEC concept of a power station unit has been deleted, generators and transformers being treated independently. This results in a different treatment of faults around power station units.
- (ii) The concept of  $I^2t$  (joule integral) of the short-circuit has been substituted for the thermal equivalent short-circuit current in IEC 865, which permits a uniform presentation of results with regard to both fuse and circuit-breaker characteristics.
- (iii) The reader is provided with data to be assumed in the absence of known data. This is particularly useful for calculations requiring zero-sequence data.
- (iv) Values of the voltage factor ( $c$ ) have been chosen to be representative of Australian practice.
- (v) A more general equation has been provided for overhead line impedance.
- (vi) Figure 8.2 for determination of the type of short-circuit producing the highest current when the phase angles of the sequence impedances are equal, has been redrawn to cover a wider range, allowing an improved appreciation of the relative significance of line-to-line-earth faults.
- (vii) Appendix A has been included to cover standard calculations on a per unit basis.
- (viii) Appendix C has been included showing equivalent circuits for the determination of zero-sequence short-circuit currents in transformers.
- (ix) The Appendices D and E provide different examples for the calculation of short-circuit currents on ohmic and per unit bases respectively.

### © Copyright — STANDARDS AUSTRALIA

Users of Standards are reminded that copyright subsists in all Standards Australia publications and software. Except where the Copyright Act allows and except where provided for below no publications or software produced by Standards Australia may be reproduced, stored in a retrieval system in any form or transmitted by any means without prior permission in writing from Standards Australia. Permission may be conditional on an appropriate royalty payment. Requests for permission and information on commercial software royalties should be directed to the head office of Standards Australia.

Standards Australia will permit up to 10 percent of the technical content pages of a Standard to be copied for use exclusively in-house by purchasers of the Standard without payment of a royalty or advice to Standards Australia.

Standards Australia will also permit the inclusion of its copyright material in computer software programs for no royalty payment provided such programs are used exclusively in-house by the creators of the programs.

Care should be taken to ensure that material used is from the current edition of the Standard and that it is updated whenever the Standard is amended or revised. The number and date of the Standard should therefore be clearly identified.

The use of material in print form or in computer software programs to be used commercially, with or without payment, or in commercial contracts is subject to the payment of a royalty. This policy may be varied by Standards Australia at any time.

## CONTENTS

|  | <i>Page</i> |
|--|-------------|
| FOREWORD .....   | 5           |
| 1 SCOPE AND GENERAL  |             |
| 1.1 Scope .....  | 6           |
| 1.2 Referenced documents .....                                       | 6           |
| 1.3 Definitions .....  | 6           |
| 2 NOTATION   |             |
| 2.1 General .....  | 8           |
| 2.2 Quantity symbols .....   | 8           |
| 3 CHARACTERISTICS OF SHORT-CIRCUIT CURRENTS .....                    | 8           |
| 4 OUTLINE OF METHOD OF CALCULATION                                   |             |
| 4.1 General .....  | 8           |
| 4.2 Assumptions .....  | 11          |
| 4.3 Method of calculation .....                                      | 11          |
| 4.4 Conversion of impedances, currents and voltages .....            | 11          |
| 5 MAXIMUM AND MINIMUM SHORT-CIRCUIT CURRENTS                         |             |
| 5.1 General .....  | 11          |
| 5.2 Maximum short-circuit currents .....                             | 12          |
| 5.3 Minimum short-circuit currents .....                             | 12          |
| 6 METHOD OF SYMMETRICAL COMPONENTS                                   |             |
| 6.1 General .....  | 13          |
| 6.2 Short-circuit impedances at the short-circuit location (F) ..... | 14          |
| 7 IMPEDANCES, REACTANCES AND RESISTANCES OF ELECTRICAL EQUIPMENT     |             |
| 7.1 General .....  | 15          |
| 7.2 Source networks .....  | 16          |
| 7.3 Transformers .....   | 17          |
| 7.4 Cables and overhead lines .....                                  | 19          |
| 7.5 Synchronous motors and compensators .....                        | 20          |
| 7.6 Asynchronous motors .....  | 20          |
| 7.7 Static converter fed drives .....                                | 20          |
| 7.8 Synchronous generators .....                                     | 20          |
| 7.9 Series reactors .....  | 22          |
| 7.10 Series capacitors .....   | 22          |
| 7.11 Shunt capacitors .....  | 22          |
| 8 CALCULATION OF SHORT-CIRCUIT CURRENTS IN THE FAULT                 |             |
| 8.1 Far-from-generator short-circuits .....                          | 22          |
| 8.2 Near-to-generator short-circuits .....                           | 22          |
| 8.3 Meshed and radial systems .....                                  | 22          |
| 8.4 Initial symmetrical r.m.s value ( $I_k''$ ) .....                | 24          |
| 8.5 Peak short-circuit current ( $i_p$ ) .....                       | 29          |
| 8.6 Breaking current .....   | 30          |
| 8.7 Steady-state short-circuit current .....                         | 33          |
| 8.8 Joule integral $I^2t$ of a short-circuit current .....           | 35          |
| 9 INFLUENCE OF MOTORS  |             |
| 9.1 Synchronous motors and synchronous compensators .....            | 35          |
| 9.2 Asynchronous motors .....  | 35          |
| 9.3 Static converter fed drives .....                                | 39          |

This is a free preview. Purchase the entire publication at the link below:

[Product Page](#)

- 
- [Looking for additional Standards? Visit Intertek Inform Infostore](#)
  - [Learn about LexConnect, All Jurisdictions, Standards referenced in Australian legislation](#)
-